

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7165-0067:144

Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Siemens Building Technologies Inc., Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

DESIGN: Model MXL and MXL-IQ fire alarm control units. Coded or noncoded; local, auxiliary, remote and central station proprietary service; automatic, manual waterflow, releasing service and sprinkler supervisory service when used as a remote station (protected premise) unit or proprietary fire receiving unit. Refer to listee's data sheet for additional detailed product description and operational considerations. Basic components:

MMB-1 ¹ , *-2 ¹ , *-3 ¹ / SMB-1 ² , -2 ² , *-3 ²	Main Control Board
MKB-1 ¹ , -2 ¹ , -4 ² , *-5 ¹ , *-6 ²	Keyboard/Annunciator Panel
MPS-6, -12	Power Supply
CRM-4	Relay Module
CSM-4	Signal Module
CZM-4	Conventional Zone Module
BTX-1, BP-61	Battery Set Module
MSE-2 ¹ , -3 ² , *-3M ²	Enclosure
*MSE-3M-D	Enclosure Door
Silent Knight 5128, 5129	Dialer/DACT (Listing No. 7300-0559:120)

¹ - For use with Model MXL only.

² - For use with Model MXL-IQ only.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed initiating and indicating devices. See (CSFM Listing No. 7300-0067:172) for optional control unit accessories. Refer to listee's Installation Instructions Manual for details.

*These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

This control unit meets the requirements of UL-864, 8th Edition Standards.

*Rev. 01-02-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 4, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division